App. F. IX—4

1955.SB
(FTB)

File No. UH. 55
Serial Nos. 38, 92
107, 111

Previous References.
FTB. 19 55-41
FTB 13 51 16

Later References.
UH 8@7M57

MYSORE GOVERNMENT SECRETARIAT

Serial Nos. 4

16

Part B for August 86

SUBJECT

Estimate for Rs 30,000/- for Providing underground drainage in Jayanagar Extension, Kejsore

WD 05150—GPB—35,000—21-8-56

L 8862 - 65 24.8.86

The Chairman, M.T.B
" C.S.A)
" C.R
" Municipal Commissioner
Kejsore city Municipality
(Thro. the Deputy)

Nagarathna
24/9/86

M. S APF. F. 111—1]

MYSORE GOVERNMENT SECRETARIAT.

NOTES.

File No.

FILE HEADING.

FROM Dy. Chairman City Corp Mysore

No. Dy. C. 140/55-6 Dated 28-11-55 Received 3.12.55

Diary No. 6433 | Enclos. Records Spare copies | Serial No.

BRIEF ABSTRACT OF LETTER

Estimate for Rs 501000/- for providing underground drainage in Jayanagar Extension, Mysore.

NOTES AND ORDERS.

Submitted:- Collection relating to the issue of G.O.No L 8582-85/ SFB 13-51-16 dated 10.11.51 is pending with Dy Secy Rs 4208 only.

Sub Reg (F) 56/22-12-55 If the note will be confirmed if approved on receipt of G.O No 246/19.12.55 this may be referred to the C.E. for scrutiny in the meanwhile

Office of the Chief Engineer of Hydrotor, Bangalore

for orders

Forwarded unofficially to the Chief Engineer Hydro Bangalore for favour of Scrutiny

Dy Secy to Govt Edn, Lab

Remarks

NOTES—First Sheet

WD 04864—GPB—20,000—22-1-54

Estimate for Rs 50,000/- for providing underground drainage in Jayanagar Extension

V

File No. 6433 MC of 195 | Mysore Government Secretariat

Memo.No. U.C. | 2736 /GI. dated 20-3-1956.
Revised

Returned.

(4) The estimate is scrutinised for Rs.50,000/- (Rs. fifty thousand only).

(5) The question of providing flushing tanks may be examined and provided wherever the velocity in the sewer is low, to create flushing.

EDUCATION & L.S.G. SECRETARY
22 MAR 1956
Government of Mysore

H Ananthachar 9/3/56
(H.- Ananthachar)
Chief Engineer of Mysore.

To

The Secretary to Government,
Education & LSG Departments,
Bangalore.

9/3/56

MG.1/.19.3.

(6) Please see flag "D" of column prop for G.O.No. LSG 28-8 SY dated 10.11.54 according sanction to an estimate for Rs 218,600/- for forming layers of cuts in Jayanagara. SYB 13-51-16

(7) The Chairman has reported that in the original sanctioned estimate a sum of Rs 58,000/- has been earmarked for laying underground drainage pipelines. The detailed estimate sent for underground drainage is Rs 50,000/-. This has been scrutinised by the CE.

(8) Sanction may perhaps be accorded to the detailed estimate as scrutinised by the CE with the remarks made by him in Para (5) above for orders

(9) The estimate for

LSG 13 Ms 27/3

Mysore Government
Secretariat

Estimate for Rs. 50,000/- for providing lined storage in Jayanagar Extension scheme

File No. 6433 ME—3760 of 195

[App. F. III 2

3

Serial No.

Rs 50,000/- may be sanctioned. The observations of the CE will be communicated

9/4

(Secy (Edn & Agy))

10) May be made as above

14.4.1956

11) 20/4

12) 20.4.56

13) May lie over for the present

27.4.56

4.5.56

21/5

14) Submitted with a d/o letter to the Chairman MTB for kind approval

14/5

15) Issued

23/5/56

Mg 14/5

Inasmuch as Govt. Circle has the matter may lie over for the present

Hd of the Chairman MTB

L 4053/MTB 14-55-922

Note.—Contn. Sheet

Estimate for Rs 50,000/- for providing underground drainage in Jagadguru Sannidhi, Nanjangud

Mysore Government Secretariat

File No 6433 ME V 360 J 2550 of 195

Serial No.

Letter No D2 C 140/53-58 dated 16-6-58 from the Chairman MMB.

Submitted:- 16) The chairman MMB has sent his views on the various provisions in the amended estimate for which details have now been got up and technical sanction required. He further wants that all amenities should be provided before disposing of the site or production from Govt and solicits technical sanction for the detailed estimate which is provided for in the main estimate for Rs 50,000 and also for the amenities - Ref para (13)

Page 8

17) In these orders whether the estimate for Rs 50,000 may be sanctioned for reasons stated by the chairman in his letter dt 16/6/56. Ref para 13

23/7/58

Secy (RSG) 18) In the circumstances sanction may be accorded. (Para 13)

24.7.58

Minister (RSG)

25/7/58

19) 6/8/58

EDUCATION & S. G. SEC. 4948 2 1958 GOVERNMENT OF MYSORE

OFFICE OF THE MINISTER FOR PUBLIC HEALTH & LOCAL-SELF GOVERNMENT. 27 JUL 1958 No. 4948 S. S.

WD 0260—GPB—P. Z. S. 1,30,000—21-5-55.

Mysore Government Secretariat

Estimate for Rs 50,000/- for providing Underground drainage facilities to Jayanagar

2250 ml File No. of 195 [App. F. III 2

Layout

Serial No.

20) Submitted with a dft G.O. for kind approval

Ref Para (17 to 19)

21)

Rs 8/9/8

M. 9/8

16.8.80

According Sanction is accorded for Rs 50,000/- as recommended by the C.E.

L 8862-65/ 408 14-15=111 dt 24.5/56

Forwarded to the Chairman MSDS Ltd.

1) Controller F&A Bldg

2) C.E. Mysore Bldg

3) Mr. Consultant Mysore city with this file for information

B'lore 25/8

(1) 6433

No. D2.C.140/55-56.

Encl. 1. Estimate,(2) Plan, (3) Report, (4)Calculation sheet,(5) Abstract manhole statement,(6)Levels of Manholes, (7) Discharge statement, (8) T.B.R.Copy

OFFICE OF THE CHAIRMAN,
CITY IMPROVEMENT TRUST BOARD.
POST BOX NO. 55, MYSORE.

Dated 28th November 1955.

FROM

SRI S. LINGANNA,
Chairman, City Improvement Trust Board,
MYSORE.

TO

EDUCATION SECRETARIAT 30 NOV 1955 MYSORE

Sri.D.M.Krishnan, B.A.,I.A.S.,
Secretary to the Government of Mysore.
Education & Local Self-Government Departments
BANGALORE.

SIR,

9 T B. 14-55 38

Subject : Estimate for Rs.50,000/- for providing underground drainage in Jayanagar Extension,Mysore.

Plos "D" Adverting to Government Order No.L.8582-85/I.T.B.13-51-16 dated 10-11-1951, sanctioning an estimate for Rs.2,18,600/- for forming layout of sites in further extension of Jayanagar, I write to forward herewith a detailed estimate for Rs.50,000/- for the above work, as approved by the Board of Trustees, at its meeting held on 31-10-1955, vide resolution No.260, copy enclosed for ready reference.

In the original sanctioned estimate, a sum of Rs.58,000/- has been ear-marked for laying underground drainage sublines.

As the layout works are under progress and the formation of roads and drains has been completed, it is now proposed to lay underground sewer lines in the newly formed roads and ultimately link to southwest outfall.

In the above circumstances, I request you kindly to obtain and communicate at a very early date, the approval of Government to the detailed estimate, against the lumpsum provision referred to above.

Yours faithfully,

S. Linganna.
(S.Linganna) 28/11
Chairman.

DVS)

City Improvement Trust Board, Mysore. 27

Dated ....

Extract from the Proceedings of the Ordinary Meeting of the Board of Trustees for the Improvement of the City of Mysore, held on 21-10-1955.

XXXX XXXX XXXX

260: Detailed estimate for Rs.50,000/- for providing underground sewage lines to further extension of Jayanagar and office note thereon.

Approved. Recommended to Government

Sd/S.Linganna,
Chairman.
31-10-55.

XXXX XXXX XXXX

"Copy"

S. Linganna.
CHAIRMAN 28/11

DVS)

City Improvement Trust Board

(2)

MYSORE,

Dated *195*

Report to accompany the estimate for providing underground drainage sewer lines in Jayanagar Extension.

Jayanagar Extension, which is situated to the west of Krishnamurthypuram, is a new layout under formation for which an estimate has been sanctioned for Rs.2,18,000/-, with a lumpsum provision of Rs.58,000/- for providing underground drainage works in the above said area. The formation of the layout is almost completed and it is right time now to take up the underground drainage works, before the houses are constructed in the area.

This estimate is got up for providing street sewer lines and for providing house connections for 276 houses Since block No.1 is already sewered and the sewage from half of the protion of block No.1 is led on to the main sewer line, which ultimately temminates at the sewage farm situated to the south of Mysore, this estimate provides for underground works for the whole area except for a portion of block No.1.

While preparing the project, advantage is taken of the main outfall line, proposed to run by the side of the layout and street sewers are connected in four places to the main outfall line, to save the dead lengths of the sewer line.

Since there is a railway line to the east of the layout, which is also the ridge line, all the street sewers in section 4 is commenced with the inspection chamber instead of manhole, to save the cost of manhole frame and cover.

P.T.O.

The estimate is got up at the current sanctioned schedule of rates for the year 1955-56.

Trust Board Engineer.

DVS)

360

(5)

No. D2:C.140/55-56.
Encl.

OFFICE OF THE CHAIRMAN,
CITY IMPROVEMENT TRUST BOARD
POST BOX NO. 55, MYSORE.

FROM

SRI S. LINGANNA,
Chairman, City Improvement Trust Board,
Dated 4th April 1956.
MYSORE.

To

Sri.B.M.Krishnan, B.A., I.A.S.,
Secretary to the Government of Mysore.
Education & Local Self-Government Departments,
BANGALORE

SIR,

Subject: Estimate for Rs.50,000/- for providing underground drainage in Jayanagar Extn, Mysore.

I write to invite your kind reference to this office 6433 letter of even No. dated 28-11-1955 on the above subject, and request you kindly to obtain and communicate the approval of Government to the estimate at a very early date

Yours faithfully,

S. Linganna
(S.Linganna)
Chairman.
4/4/56.

DVS) submitted in the main file bearing Dop 6433 re Lr seen submitted to me Lay on 10.4.56. the receipt of the main file may be acknowledged

---

Formally Lay

This will be placed in the main file after its return with final orders

Ms 18/4

M. G. S. App. f. G. 3]

MYSORE GOVERNMENT

SECRETARIAT.

(~~Continuation sheet draft form~~).

No. L 4053/PTB. 14-55-92 (D)

&

To

The Chairman MDA

Sir,

Subject – Estimate for Rs 50,000/- for providing underground drainage in Jayanagar Extension Mysore.

Reference your letter No. Dy C 140 55-52 dated 28. 11. 55 and subsequent reminder.

I am directed to state that Govt consider the matter may lie over for the present.

Yours faithfully

28/12

for Secy Edn (PTB) Dept

R 14/5

WD 0255 -GPB--PZS-1,20,000—1-7-55.

GOVERNMENT OF MYSORE.

(7)

No.L-4053/97A-16-55-56 **Mysore Government Secretariat,**

Bangalore, dated..6.6.....195 6

NOTIFICATION.

From

The Secretary to the Government of Mysore,
Education & LSG Departments.

To

The Chairman,
City Improvement Trust Board,
MYSORE.

Sir,

Sub:- Estimate for Rs.59,000/- for providing underground drainage in Jayanagar Extension, Mysore

Ref: Your letter No.D2.C.140/55-56 dated 28-11-55 and subsequent reminder.

I am directed to state that Government consider ~~x~~ that the matter may lie over for the present.

Yours faithfully,

3/5

(V.Hanumanthappa)
for Secretary to Government,
Education & LSG Departments.

bws:30.5.

6433/360 9TB. 14-55-107 (8)

No. D2.C.140/55-56.
Encl.

EDUCATION & L.S.G. SECRETARIAT 19 JUN 56

MYSORE GOVT. No. 2250

OFFICE OF THE CHAIRMAN,
CITY IMPROVEMENT TRUST BOARD,
POST BOX NO. 55, MYSORE.

Dated June 16th, 56.

FROM

SRI S. LINGANNA,
Chairman, City Improvement Trust Board,
MYSORE.

To

Sri B.M.Krishnan, B.A., I.A.S.,
Secretary to the Government of Mysore.
Education & Local Self-Government Departments
BANGALORE.

SIR,

Subject : Estimate for Rs. 50,000/- for providing underground drainage facilities to Jayanagar layout.

× Flag "G"

With reference to your letter No.L.4053/ITB 14-55-92 dated 1-6-56 intimating that the matter may lie over for the present, I write to Flag "H" invite kind reference to your letter No.L. 3541 × dated 22-5-56 regarding the disposal of sites in the above extension and to state as follows:-

This is one of the lumpsum provisions in the sanctioned estimate for which details have how been got up and technical sanction is required. The works connected with the formation of roads, drains etc., have all been completed and laying of underground drainage and water supply sub mains are the only two works that remain to be done. As kindly observed by Government already, that all amenities should be provided prior to taking up the disposal of sites, the Board in pursuance and in order to implement Government directions mentioned above, has resolved in T.B.R.No.51 dated.30-5-56 to expedite these works. The water supply Department has also been requested to prepare an estimate for laying the water supply sub mains and further action will be taken in that direction also. Hence technical sanction to the detailed estimate which is provided for in the main sanctioned layout estimate, is now solicited.

Yours faithfully,

S. Linganna 18/6.
(S.Linganna)
Chairman.

DVN)

M. G. S. App. F VI—G. 2]

SUBJECT.....

.....

.....

Diary No. of letter replied to.....

Mysore Government Secretariat

( )

the 195

Date of issue.....195

Signed by.....

May this be—

(i) printed?
(ii) treated as a Standing Order?
(iii) published in the Gazette, English Part?
(iv) translated?
(v) placed at the disposal of the Press?
(vi) published in the Gazette, Kannada Part?

Section ITB

Serial No. 14-55

File No. 111

Proceedings of the Government of Mysore

Read— G.O. No. D 8582-85/ITB 13-51. dated 10th November 1951 according sanction to an estimate for Rs 2,18,600 for forming layout of site on further extension of Jayanagar Mysore

Order thereon.—No. (2) Correspondence ending with letter No. D2.C. 1140/55-6 dated 16th June 1956 from the chairman MTB forwarding for sanction a detailed estimate for Rs 50,000/- for providing underground drainage in Jayanagar extension Mysore as approved by the Board of Trustees

As against the sum of Rs 58,000/- provided for the work in the estimate Annexed to the G.O. first above and showing that as the work connected with the formation of Roads, Drains etc have all been completed it is proposed to lay underground sewerlines in the newly formed Roads and ultimately link to South West outfall

(3) No. 12736/G.I. dated 20th March 1956 of the Chief Engineer sanctioning the estimate duly certified for Rs 50,000/- with Observation

Endorsed 8862-65 D. 24-8-56.

The estimate for Rs 50,000/- (six lakhs) as certified by the C.E is Annexed.

The question of providing flushing tanks may be examined and provided wherever the Velocity in the sewer line is low to create flushing.

List of Enclosures.

Copied by

Examined by

WD 0259—GPB—P.Z.S.—1,00,000—23-2-56

for by sec Exec engr

The chairman MMB with records
The consltg Engr Blore
The CE Mysore Blore
The Secy Mysore Housing Bldg Co Ltd
The President

11

PROCEEDINGS OF THE GOVERNMENT OF MYSORE.

R e a d :

G.O.No.L.8582-85/ITB.13-51-6 dated the 10th/15th November 1951 according sanction to an estimate for Rs.2,18,600/- for forming layout of sites in further extension of Jayanagar, Mysore.

2. Correspondence ending with letter No.B2.C.140/55-6 dated the 16th June 1956 from the Chairman, City Improvement Trust Board, Mysore, forwarding for sanction a detailed estimate for Rs.50,000/-for providing underground drainage in Jayanagar Extension, Mysore, as approved by the Board of Trustees as against the sum of Rs.58,000/- provided for the work in the estimate sanctioned in the Government Order read above and stating that as the works connected with the formation of roads, drains, etc., have all been completed it is proposed to lay underground sewer lines in the newly formed roads and ultimately link to South West out outfall.

3. Un-official Note No.12735/GI. dated 20th March 1956 of the Chief Engineer of Mysore, returning the estimate duly scrutinised for Rs.50,000/- with observations.

Order No.L. 8862-65/971 14-58-11

Dated, Bangalore, the 24-8-56.

The Estimate for Rs.50,000/- (Rupees fifty thousand only) as scrutinised by the Chief Engineer of Mysore is sanctioned.

The question of providing flushing tanks may be examined and provided wherever the velocity in the sewer is low to create flushing.

(P.HONNAPPA)
for Secretary to Government,
Education & LSG Departments.

To

The Chairman, City Improvement Trust Board, Mysore, with records.
The Controller, State Accounts Department, Bangalore.
The Chief Engineer of Mysore, Bangalore.
The Municipal Commissioner, Mysore City Municipality -- through the President.

bvs:20.8(7)